

Certificate of Compliance

Certificate: 2505549 Master Contract: 187963

Project: 2505549 **Date Issued:** May 28, 2012

Issued to: MECC ALTE S.p.A.

Via Roma 20

CREAZZO (VI) 36051

ITALY

The products listed below are eligible to bear the CSA Mark shown



Ghíslain Foulem Issued by: Ghislain Foulem

PRODUCTS

CLASS - 4211 01 - Motors and Generators

Self Regulating Electric Generators, 2 or 4 poles, indoor use, continuous duty, flange mounted, three phase or three phase, single phase connected; insulation Class H; 40°C rated ambient:

Part A

- Series NPE 32/4, 400V, 50Hz, 7.5 27.5kVA max or 480V, 60Hz 9.0 34.0kVA max, 4 pole; three phase.
- Series NPE 32/4, 230V, 50Hz, 5.0 18.3kVA max or 240V, 60Hz, 6.0 22.6kVA max, 4 pole; three phases, single phase connected.
- Series NPE 31/2, 400V, 50Hz, 8.0 32kVA max or 480V, 60Hz, 10 38.4kVA max, 2 pole three phase.
- Series NPE 31/2,230V, 50Hz, 5.3 21.3kVA max or 240V, 60Hz, 6.6 25.5kVA max, 2 pole, three phase, single phase connected

<u>Part B</u> Synchronous Electric Generators, 2 or 4 poles, indoor use, continuous duty, flange mounted, Single phase insulation Class H; 40°C rated ambient:

DQD 507 Rev. 2009-09-01 Page

Certificate: 2505549 **Project:** 2505549



Master Contract: 187963

Date Issued: May 28, 2012

• Series NPE 31/2, 230V, 50Hz, 7.0 – 25.0kVA max or 240V, 60Hz, 8.4 – 30.0kVA max, 2 pole

• Series NPE 32/4, 230V, 50Hz, 6.4 – 22.5kVA max or 240V, 60Hz, 8.4 – 26.5kVA max, 4 pole

<u>Part C</u> Synchronous Electric Generators, 2 poles, indoor use, continuous duty, flange mounted, Single phase, 230/240Vac max., 50/60Hz, insulation Class H; 40°C rated ambient:

• Series SPE 16F single phase, 50Hz, 2.0 – 5.0kVA max or 60Hz, 2.5 – 6.0kVA max.

• Series SPE 20FS single phase, 50Hz, 5.8 – 8.2kVA max or 60Hz, 7.0 – 10.0kVA max.

APPLICABLE REQUIREMENTS

CAN/CSA – C22.2 No. 0.4-04 Bonding of electrical equipment

CAN/CSA – C22.2 No. 100-04 Motors and Generators

DQD 507 Rev. 2009-09-01 Page 2



Supplement to Certificate of Compliance

Certificate: 2505549 Master Contract: 187963

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2505549	May 28, 2012	CSA Original Certification Self Regulating Electric Generators

DQD 507 Rev. 2009-09-01 Page 1